



**Notes:**

1. Refer to CORED Standard 514 for grounding specifications.
2. Refer to CORED Standard 516 for 4-point junction installation.
3. Refer to CORED Standards 607A & 607B for 3 phase primary cable.
4. Interior gravel level must cover holes on sides of vault.

APPROVED UNITS	
MANUFACTURER	STANDARD & TAPPED VAULTS
HIGHLINE.....	HL45 OR HL48M
ELECTRI-GLASS.....	BP2000
CUSTOM COMPOSITES.....	RFB 43-37-32-3226
ELECTROMOLD.....	EFBT374332-2632-200
NORDIC.....	GS-37-43-32A-CE-2

## PULL VAULT INSTALLATION

REV	DATE	DRWN	APPD	DESCRIPTION	SUPERSEDES: 509.S01.R04	SCALE: 1:20
1	1-1-10	PWS	MEB	HANDBOOK UPDATE.	DRWN: J.R.W.    APPD: MEB	DATE: 05/25/07
-					CORED STANDARD NUMBER <span style="font-size: 1.5em; color: blue;">515A R 1</span>	