



Notes:

1. Refer to CORED Standard 514 for grounding specifications.
2. Adjust conduit for field conditions.
3. Interior gravel level must cover holes on sides of vault.

APPROVED UNITS	
MANUFACTURER	STANDARD & TAPPED VAULTS
HIGHLINE.....	HL45 OR HL48M
ELECTRI-GLASS.....	BP2000
CUSTOM COMPOSITES.....	RFB 43-37-32-3226
ELECTROMOLD.....	EFBT374332-2632-200
NORDIC.....	GS-37-43-32A-CE-2

TRANSFORMER VAULT INSTALLATION

REV	DATE	DRWN	APPD	DESCRIPTION	SUPERSEDES: 509.S01.R04	SCALE: 1:20
1	1-01-10	PWS	MEB	HANDBOOK UPDATE.	DRWN: J.R.W. APPD: MEB	DATE: 05/25/07
-					CORED STANDARD NUMBER 515B R 1	