



APPROVED UNITS	
<u>MANUFACTURER</u>	<u>NUMBER</u>
NORDIC	GS-85-23-30

Notes:

1. Refer to CORED Standard 514 for grounding specifications.
2. Bed sleeve with 4" of compacted gravel.
3. Place maximum 4" of tamped gravel inside of sleeve.
4. Conduit is to protrude 2" above tamped gravel.
5. This vault is typical for 3 phase, 200A primary.

SECTOR VAULT FOR 4 POINT MULTIPOINT JUNCTIONS

REV	DATE	DRWN	APPD	DESCRIPTION	SUPERSEDES: S607.RWS.R13	SCALE: NTS	
1	1-01-10	PWS	MEB	HANDBOOK UPDATE.	DRWN: MESA	APPD: MEB	DATE: 3-1-07
-					CORED STANDARD NUMBER 607A R 1		