



**Notes:**

1. 12' Minimum vertical clearance (including drip loop) over residential property accessible to pedestrians only. Refer to NESC Table 232-1 if building height does not allow this clearance.
2. 12' Minimum vertical clearance over residential property accessible to pedestrians. NESC Table 232-1
3. 16' Minimum vertical clearance over residential private driveways. NESC Table 232-1
4. 18' Minimum vertical clearance over roads, streets, and other areas subject to truck traffic. NEC 230.24(B)(4)
5. 11' Minimum vertical clearance over adjacent, accessible roofs. NESC Table 234-1
6. 10' Minimum vertical clearance over attached balconies, porches, or decks readily accessible to pedestrians. NESC 234(C)(3)(d)(1)
7. 3' Minimum vertical and horizontal clearance from window or door openings. NESC 234(C)(3)(d)(2)

REV	DATE	DRWN	APPD	DESCRIPTION
-				
-				

**SERVICE-DROP CONDUCTOR  
CLEARANCES**

<b>SUPERSEDES:</b>		<b>SCALE:</b> NTS
DRWN: PWS	APPD: MEB	DATE: 3/10/10
<b>CORED STANDARD NUMBER</b>	<b>641 R 0</b>	