



APPROVED UNITS		
<u>MANUFACTURER</u>	<u>NUMBER</u>	<u>COVER</u>
CDR	PA10-1730-18	--
HIGHLINE	CHA1730185E1	--

Notes:

1. Keep conduit between 2 and 4 inches above the bottom of the pedestal.
2. The entire pedestal lid is to remain above grade.
3. This drawing is a recommended construction drawing. If this drawing is deviated from and the cable cannot be pulled, it is the responsibility of the customer to resolve the problem so the cable can be pulled through the conduit.
4. Use Highline CHA1730185E1, CDR PA10-1730-18, or CORED approved equivalent.
5. Larger secondary pedestals are required for three or more conduits. Refer to Standard Number 518.

SMALL SECONDARY PEDESTAL INSTALLATION

REV	DATE	DRWN	APPD	DESCRIPTION	SUPERSEDES: 507.S01.R03	SCALE: NTS
3	1-01-10	PWS	MEB	HANDBOOK UPDATE.	DRWN:JWarner	APPD:MEBeams
4	9-29-10	PWS	MEB	DIMENSION CORRECTIONS	CORED STANDARD NUMBER	517 R 4