

CITY OF OAK RIDGE ELECTRIC DEPARTMENT Interconnection Agreement for Distributed Generation

This Interconnection Agreement (“Agreement”) is made and entered into this ____ day of _____, 20____, by the City of Oak Ridge Electric Dept., (“CORED”), a corporation organized under the laws of the State of Tennessee and _____, who is hereinafter referred to as “Participant”. CORED and Participant may be collectively referred to as “Parties”, or individually as a “Party”.

WHEREAS, the Participant has requested interconnection services from CORED to self-generate by the means of renewable generation that is owned by the Participant or a third party (see Interconnection Application) at the Participant’s presently metered location, which is _____.

Now, therefore, for and in consideration of the mutual covenants and agreements set forth herein, the Parties agree as follows:

1. Scope of Agreement

- 1.1. This Agreement is applicable to conditions under which CORED and the Participant agree that one or more generating systems and all related interconnection equipment (described in the Interconnection Application and hereinafter referred to as “Qualifying System”) located at Participant’s presently metered location with gross power rating of ____kW and to be interconnected at ____kV may be interconnected to the CORED’s electric power distribution system (“System”). Execution of this agreement allows the Participant to proceed with procurement and installation of the system **but Participant is not allowed to proceed with parallel operation until Distributor has received a completed Certificate of Completion, Distributor has conducted an onsite inspection and witnessed any required commissioning test or waived such test, and has given Participant written authorization to proceed with parallel operation.**

2. Establishment of Point of Interconnection

- 2.1. The point where the electric energy first leaves the wires or facilities owned by CORED and enters the wires or facilities provided by Participant is the "Point of Interconnection." CORED and Participant agree to interconnect the Qualifying System at the Point of Interconnection in accordance with the Distributor's rules, regulations, by-laws, and rates ("Rules") which are incorporated herein by reference and the generator and all related interconnection equipment will comply with CORED's Interconnection Procedures.

3. General Responsibilities of the Parties

- 3.1. CORED has reviewed the proposed generation and related equipment as described in the Application for compliance with CORED's Interconnection Procedures and approved the Qualifying System for interconnection based on one of the following conditions:
 - 3.1.1. Qualifying System has been certified as meeting the applicable codes and standards and has passed any applicable Screening Process, or
 - 3.1.2. CORED in agreement with Participant has conducted additional engineering evaluations or detailed impact studies and any necessary System upgrades or changes identified by these additional studies have been implemented and Participant has paid for such changes where necessary;
- 3.2. Participant shall comply with all applicable laws, regulations, zoning codes, building codes, safety rules and environmental restrictions, including the latest version of the National Electrical Safety Code, National Electric Code, codes issued by Underwriter's Laboratories ("UL"), the Institute of Electrical and Electronics Engineers ("IEEE"), and the American National Standards Institute ("ANSI") that are applicable to the design, installation, operation and maintenance of its Qualifying System.
- 3.3. The Participant shall provide Local Building Code Official inspection and certification of installation forms to the Distributor. The certification shall reflect that the code official has inspected and certified that the installation was permitted, has been approved, and has met all electrical and mechanical qualifications.
- 3.4. After installation, the Participant shall return the Certificate of Completion to CORED. Prior to parallel operation, CORED may inspect the Qualifying System for compliance with standards which may include a witness test. CORED must provide written authorization before Participant can begin parallel operation.
- 3.5. Participant shall conduct operations of its Qualifying System in compliance with all aspects of the Rules and in accordance with industry standard prudent engineering practice and must comply with the latest version of IEEE 519, UL1741, IEEE1547, and any other applicable codes and standards.
- 3.6. **The Participant shall be responsible for protecting its renewable generation equipment, inverters, protective devices, and other system components from damage from the normal and abnormal conditions and operations that occur on the System in delivering and restoring power; and shall be responsible for ensuring that the Qualifying System is inspected, maintained, and tested on an ongoing basis in accordance with the manufacturer's instructions to ensure that**

it is operating correctly and safely. CORED has the right to request and receive copies of the test results.

4. Inspection and On-Going Compliance

- 4.1. CORED will provide Participant with as much notice as reasonably practicable; either in writing, e-mail, facsimile or by phone as to when CORED may conduct inspection and/or document review. Upon reasonable notice, or at any time without notice in the event of an emergency or hazardous condition, CORED shall have access to the Participant's premises for the purpose of accessing the manual disconnect switch, performing an inspection or disconnection, or, if necessary, to meet CORED's legal obligation to provide service to its customers.

5. Manual Disconnect Switch

- 5.1. **Participant must install a manual, lockable, visible load break disconnect switch between the generation source and CORED's system that is visibly marked "Participant Generation Disconnect".** The disconnect switch shall be mounted separate from but adjacent to CORED's meter socket. The Participant shall ensure that such manual disconnect switch shall remain readily accessible to CORED and be capable of being locked in the open position with a single CORED utility padlock. **A permanent, weatherproof single line diagram of the facility must be located adjacent to the disconnect switch. Names and current telephone numbers of at least two persons authorized to provide access to the facility that have authority to make decisions regarding the interconnection and operation of the Qualifying System will be included.**

6. Disconnection/Reconnection

- 6.1. CORED may open the manual disconnect switch or disconnect the Participant's meter, pursuant to the conditions set forth in Section 6.2 below, isolating the Qualifying System, without prior notice to the Participant. To the extent practicable, however, prior notice shall be given. If prior notice is not given, CORED shall at the time of disconnection leave a door hanger notifying the Participant that its Participant-owned renewable generation has been disconnected, including an explanation of the condition necessitating such action. As soon as practicable after the condition(s) necessitating disconnection has been remedied, CORED will unlock the disconnect switch so Participant may reenergize the Qualifying System.
- 6.2. CORED has the right to disconnect the Participant-owned renewable generation at any time. Some examples of situations that may require disconnect are:
 - 6.2.1. Emergencies or maintenance requirements on CORED's system;
 - 6.2.2. Hazardous conditions existing on CORED's system due to the operation of the Participant's generating or protective equipment as determined by CORED; and
 - 6.2.3. Adverse electrical effects, such as power quality problems, on the electrical equipment of CORED's other electric consumers caused by the Participant-owned renewable generation as determined by CORED.

7. Modifications/Additions to Participant-owned Renewable Generation

- 7.1. If the Qualifying System is subsequently modified in order to increase or decrease its gross power rating or any components are changed, the Participant must provide CORED with written notification that fully describes the proposed modifications at least thirty (30) calendar days prior to making the modifications. **Participant is not allowed to proceed with parallel operation of modified qualifying system until authorized by CORED.**

8. Indemnity

- 8.1. Participant agrees to release, indemnify, and save harmless CORED, and their respective agents and employees from all liability, claims, demands, causes of action, costs, or losses for personal injuries, property damage, or loss of life or property, sustained by Participant, Participant's agents and family, or third parties arising out of or in any way connected with the installation, testing, operation, maintenance, repair, replacement, removal, defect, or failure of Participant's Qualifying System. The obligations of this section 8.1 shall survive termination of this agreement.

9. Assignment

- 9.1. The Interconnection Agreement shall not be assignable by either party without thirty (30) calendar day notice to the other Party and written consent of the other Party, which consent shall not be unreasonably withheld or delayed.
- 9.2. An assignee to this Interconnection Agreement shall be required to assume in writing the Participant's rights, responsibilities, and obligations under this Interconnection Agreement.

10. Insurance

- 10.1. Distributor requires the following levels of Liability Insurance for Personal Injury and Property damage during the entire term of this Interconnection Agreement.

10.1.1 Generation over 30kW - Participant maintains an amount of not less than

Comprehensive General Liability:

Per Occurrence Limit	\$1,000,000
General Aggregate Limit	\$2,000,000
Products/Completed Operations Aggregate Limit	\$2,000,000
Fire Damage Legal Liability Limit	\$1,000,000
Medical Expense Payments	\$5,000

11. Effective Term and Termination Rights

- 11.1. This Agreement becomes effective when executed by both Parties and shall continue in effect as long as the Qualifying System is capable of operation and connected to CORED's System. If CORED incurs any costs as a result of termination of this Agreement, Participant shall reimburse CORED for such costs. The participant may not start a new parallel operation agreement for a system currently participating in another generation program or TVA program. CORED reserves the right to terminate the agreement if the Participant is non-compliant.

12. Entirety of Agreement and Prior Agreements Superseded

- 12.1. This Agreement, including the Rules, and all attached Exhibits, are expressly made a part hereof for all purposes, and constitutes the entire agreement and understanding between the Parties with regard to the interconnection of the Qualifying System of the Parties at the Point of Interconnection expressly provided for in this Agreement. The Parties are not bound by or liable for any statement, representation, promise, inducement, understanding, or undertaking of any kind or nature (whether written or oral) with regard to the subject matter hereof not set forth or provided for herein, in the Participant's Interconnection Application, Certificate of Completion, or other written information provided by the Participant in compliance with the Rules.

13. Notices

- 13.1. Notices given under this Agreement are deemed to have been duly delivered if hand delivered or sent by United States certified mail, return receipt requested, postage prepaid, to:

(a) If _____ to _____ CORED:

City of Oak Ridge Electric Dept.

100 Woodbury Lane, Oak Ridge, TN 37830

(b) If to Participant:

The above-listed names, titles, and addresses of either Party may be changed by written notification to the other.

IN WITNESS WHEREOF, the Parties have caused this Agreement to be signed by their respective duly authorized representatives.

[CORED]

[PARTICIPANT NAME]

BY: _____

BY: _____

TITLE: _____

TITLE: _____

DATE: _____

DATE: _____